

15345 - Natural Gas Polyethylene Service Line Installation		June 15, 2020															
3.3.1.4	Prior to backfilling, the trench shall be examined to ensure the main is continuously supported at all points. #12-gauge solid copper tracer wire (KUB Item #383448) shall be installed within 6 inches of the main.																
3.8.15	<p style="text-align: center;">TABLE 7: Location For Riser Installation</p> <table> <tr> <th>Riser Size</th><th>Distance To Building Wall</th><th>Distance To Fuel Line</th></tr> <tr> <td>¾ inch</td><td>12-18 inches</td><td>18 inches</td></tr> <tr> <td>1 ¼ inch</td><td>18-24 inches</td><td>36 inches</td></tr> <tr> <td>2 inch (2M and 3M Meter)</td><td>18-24 inches</td><td>36 inches</td></tr> <tr> <td>2 inch (5M and 7M Meter)</td><td>18-24 inches</td><td>72 inches</td></tr> </table>		Riser Size	Distance To Building Wall	Distance To Fuel Line	¾ inch	12-18 inches	18 inches	1 ¼ inch	18-24 inches	36 inches	2 inch (2M and 3M Meter)	18-24 inches	36 inches	2 inch (5M and 7M Meter)	18-24 inches	72 inches
Riser Size	Distance To Building Wall	Distance To Fuel Line															
¾ inch	12-18 inches	18 inches															
1 ¼ inch	18-24 inches	36 inches															
2 inch (2M and 3M Meter)	18-24 inches	36 inches															
2 inch (5M and 7M Meter)	18-24 inches	72 inches															