

15720 - Natural Gas Polyethylene Main Installation - Summary of Changes - 2021 Revision			
Change #	Section (2020 Revision)	Section (2021 Revision)	Description of Change
1	3.11 Table 4	3.11 Table 4	For 4" pipe with pipe length of 2,0001-6,500 FT, pressure test will require a project specific test plan from Gas Systems Engineering (previously 7 hour test)