

**Knoxville Utilities Board
Wastewater Technical Specifications
Summary of Revisions
March 2019**

Note: This is only a brief summary of changes associated with the KUB's recent revision/update of selected waste water focused technical specifications. Interested parties are encouraged to thoroughly review and become familiar with these revised specifications prior to bidding KUB contracts.

These revisions are current as of 3/1/19. These revisions supersede previous versions unless otherwise stated.

02534 – Wastewater Force Main

- Added requirements for tracer wire
- Added PVC pipe installation requirements
- Added DIP pipe installation requirements
- Significant modifications dealing with standards references, pipe preparation, pipe joining, connections to structures or other pipe systems, trial welds, Owner inspections, correction of deficiencies associated with HDPE pipe, etc.
- Leakage Test: added general requirements for notification, testing, leakage equation, etc.