

**Knoxville Utilities Board
Wastewater Technical Specifications
Summary of Revisions
March 2019**

Note: This is only a brief summary of changes associated with the KUB's recent revision/update of selected waste water focused technical specifications. Interested parties are encouraged to thoroughly review and become familiar with these revised specifications prior to bidding KUB contracts.

These revisions are current as of 3/1/19. These revisions supersede previous versions unless otherwise stated.

02542 – Sewer Flow Control

- Action Submittals revised to include bypass pumping checklist
- Quality Assurance section revised to require PE stamped plans on bypasses larger than 12" diameter