

**Knoxville Utilities Board  
Wastewater Technical Specifications  
Summary of Revisions  
March 2019**

---

Note: This is only a brief summary of changes associated with the KUB's recent revision/update of selected waste water focused technical specifications. Interested parties are encouraged to thoroughly review and become familiar with these revised specifications prior to bidding KUB contracts.

These revisions are current as of 3/1/19. These revisions supersede previous versions unless otherwise stated.

**02547 – Manhole Rehabilitation**

- Now a separate specification – now longer included as part of Section 02530 – Sewer Manholes
- Added hydraulic cements (leak control and void filler products) and chemical grouts to the products
- Added product descriptions, added/updated ASTM references, calcium aluminate when final coating for corrosion resistance for Spray Applied Cementitious Manhole Coating
- Manhole Vacuum Testing is aligned with language found in Section 02530 – Sewer Manholes