

**Knoxville Utilities Board  
Wastewater Technical Specifications  
Summary of Revisions  
March 2019**

---

Note: This is only a brief summary of changes associated with the KUB's recent revision/update of selected waste water focused technical specifications. Interested parties are encouraged to thoroughly review and become familiar with these revised specifications prior to bidding KUB contracts.

These revisions are current as of 3/1/19. These revisions supersede previous versions unless otherwise stated.

**02955 – Sanitary Sewer Pipebursting**

- Updated with regards to newer ASTM references for PE pipe, joining, etc.
- Service Lateral Shutdown is aligned with CIPP specification
- Internal bead removal is now required