

Addendum No. 1

Project: Webster Avenue Grinder Pump Installation
Control No: 833
Issued: To all listed plan holders
Date: March 27, 2017

This addendum forms a part of the Agreement described above. The original Contract Documents and any prior addenda remain in full force and effect except as modified by the following, which shall take precedence over any contrary provisions in prior documents.

1. Clarification Items:

- Contractor will be required to obtain the proper plumbing and electrical permits from the City of Knoxville.
- The e-one model specified comes with a 120V or 240V motor. The electric service on the Novacopy sign appears to be a single phase 120/240V. The Grinder pump motor shall be 240V.

END

Each Bidder/Proposer shall acknowledge receipt of this addendum by affixing his signature below, by noting this addendum on his Bid/Proposal Form, and by attaching this addendum to his Bid/Proposal. **Failure to acknowledge this addendum could be cause for bid/proposal rejection.**

ACKNOWLEDGMENT

The undersigned acknowledges receipt of this addendum and the Bid submitted is in accordance with information, instructions and stipulations set forth herein.

BIDDER / PROPOSER _____

AUTHORIZED SIGNATURE _____

DATE _____